

# Multi-objective Reactive Power Compensation

Benjamín Barán, *Member, IEEE*, José Vallejos, Rodrigo Ramos and Ubaldo Fernández, *Member, IEEE*.

**Abstract** — Reactive Power Compensation in Electric Systems is usually studied as a constrained Single-objective Optimization Problem where an objective function is a linear combination of several factors, such as, investment and transmission losses. At the same time, constraints limit other parameters as reliability and voltage profile.

This paper presents a new approach using Multi-objective Optimization Evolutionary Algorithms. It proposes a variant of the Strength Pareto Evolutionary Algorithm (SPEA) that independently optimizes several parameters, turning most traditional constraints into new objective functions. That way, a wide set of optimal solutions, known as Pareto set, is found before deciding which solution best combines different features.

Several sets of solutions calculated by different methods are compared to a Pareto set found with the proposed approach using appropriate test suite metrics. Comparison results emphasize outstanding advantages of the proposed computational approach, such as: ease of calculation, better defined Pareto Front and a larger number of Pareto solutions.

**Index Terms** — Reactive Power Compensation, Multi-objective Optimization, Evolutionary Algorithms.

## I. INTRODUCTION

REACTIVE Power Compensation is commonly addressed as a constrained Single-objective Optimization Problem [1–3]. It basically consists in determining an adequate location and size of shunt capacitor/reactor banks. In this context, the objective function is a linear combination of several factors, such as: investment and transmission losses, subject to operational constraints such as reliability and voltage profile [4]. Traditional Single-objective Optimization Algorithms usually provide a unique optimal solution. On the contrary, *Multi-objective Optimization Evolutionary Algorithms* (MOEA) independently and simultaneously optimize several parameters turning most traditional constraints into new objective functions. This seems more natural for real world problems where choosing a threshold may seem arbitrary [5]. As a result, a wide set of optimal solutions (Pareto set) may be found. Therefore, an engineer may have a whole set of optimal alternatives before deciding which solution is the best compromise of different (and sometimes contradictory) features. This approach has already been treated as a *Multi-objective Optimization Problem* (MOP) with two conflicting objective functions [6].

---

This work was supported by the National Computing Center (CNC) of the National University of Asuncion (UNA) – Paraguay.

B. Barán, J. Vallejos and R. Ramos are with the National Computing Center of the National University of Asuncion – Paraguay. P.O.Box 1439, San Lorenzo – Paraguay. (e-mail: {bbaran, jvallejo, rramos}@cnc.una.py).

U. Fernández is with the National Electricity Administration of Paraguay – ANDE. (e-mail: ufernandez@ieec.org).

To solve the Reactive Power Compensation Problem, this paper presents a new approach based on the *Strength Pareto Evolutionary Algorithm* (SPEA) [7], which is a MOEA with an external population of Pareto Optimal solutions that best conform a Pareto Front, provided by a clustering process that saves the most representative solutions.

## II. MATHEMATICAL FORMULATION

For the purposes of this paper, the following assumptions where considered in the formulation of the problem:

- shunt-capacitor/reactor bank cost per MVar is the same for all busbars of the power system;
- power system is considered only at peak load.

Based on these considerations, four objective functions  $F_i$  (to be minimized) have been identified [4, 8]:  $F_1$  and  $F_2$  are related to investment and transmission losses, while  $F_3$  and  $F_4$  are related to quality of service. The objective functions to be considered are:

$F_1$ : *Investment in reactive compensation devices*

$$F_1 = \sum_{i=1}^n k |B_i| \quad (1)$$

$$k = \begin{cases} \alpha & \text{if } 0 \leq B_i < B_m \\ \beta & \text{if } -B_m < B_i < 0 \end{cases}$$

s.t.:  $F_1 \leq F_{1m}$ ;

where:  $F_1$  is the total required investment;  $F_{1m}$  is the maximum amount available for investment;  $B_i$  is the compensation at busbar  $i$  measured in MVar;  $B_m$  is the absolute value of the maximum amount of compensation in MVar allowed at a single busbar of the system;  $\alpha$  is the cost per MVar of a capacitor bank;  $\beta$  is the cost per MVar of a reactor bank and  $n$  is the number of busbars in the electric power system.

$F_2$ : *Active power losses*

$$F_2 = P_g - P_l \geq 0 \quad (2)$$

where:  $F_2$  is the total transmission active losses of the power system in MW;  $P_g$  is the total active power generated in MW and  $P_l$  is the total load of the system in MW.

$F_3$ : Average voltage deviation

$$F_3 = \frac{\sum_{i=1}^n |V_i - V_i^*|}{n} \quad (3)$$

where:  $F_3$  is the per unit (pu) average voltage difference;  $V_i$  is the actual voltage at busbar  $i$  (pu) and  $V_i^*$  is the desired voltage at busbar  $i$  (pu).

$F_4$ : Maximum voltage deviation

$$F_4 = \max_i (V_i - V_i^*) = \|\mathbf{V} - \mathbf{V}^*\|_\infty \geq 0 \quad (4)$$

where  $F_4$  is the maximum voltage deviation from the desired value (pu);  $\mathbf{V} \in \Re^n$  is the voltage vector (unknown) and  $\mathbf{V}^* \in \Re^n$  is the desired voltage vector.

In summary, the optimization problem to be solved is the following:

$$\min \mathbf{F} = [F_1 \quad F_2 \quad F_3 \quad F_4] \quad (5)$$

where

$$\mathbf{F} = \left[ \sum_{i=1}^n B_i \quad P_g - P_l \quad \frac{\sum_{i=1}^n |V_i - V_i^*|}{n} \quad \|\mathbf{V} - \mathbf{V}^*\|_\infty \right]$$

is known as *objective vector*,

subject to  $F_1 \leq F_{1m}$  and the load flow equations [9]:

$$\begin{aligned} P_k &= V_k \sum_{i=1}^n Y_{ki} V_i \cos(\delta_k - \delta_i - \theta_{ki}) \\ Q_k &= V_k \sum_{i=1}^n Y_{ki} V_i \sin(\delta_k - \delta_i - \theta_{ki}) \end{aligned} \quad (6)$$

where:  $V_k$  is the voltage magnitude at node  $k$ ;  $Y_{ki}$  is the admittance matrix entry corresponding to nodes  $k$  and  $i$ ;  $\delta_k$  is the voltage phase angle at node  $k$ ;  $\theta_{ki}$  is the phase admittance matrix entry corresponding to nodes  $k$  and  $i$ ;  $P_k$  is the active power injected at node  $k$ ;  $Q_k$  is the reactive power injected at node  $k$ .

To represent the amount of reactive compensation to be allocated at each busbar  $i$ , an unknown vector  $\mathbf{B}$ , known as *decision vector* [7], is used to indicate the size of each reactive bank in the power system, i.e.:

$$\mathbf{B} = [B_1 \quad B_2 \quad \cdots \quad B_n], B_i \in \Re, |B_i| \leq B_m \quad (7)$$

The set of solutions of a multi-objective optimization

problem consists of all decision vectors  $\mathbf{B}$  for which the corresponding objective vectors  $\mathbf{F}$  can not be improved in any dimension without degradation in another. This set of decision vectors are known as *Pareto Optimal*, represented as  $P$ . The corresponding set of objective vectors  $\mathbf{F}$  calculated using equations (1) to (4) conform a set known as *Optimal Pareto Front*, denoted  $PF$  [7].

Because the *true* Pareto Optimal Set (termed  $P_{\text{true}}$ ), with its corresponding  $PF_{\text{true}}$ , are not completely known in practice without extensive calculation (computationally not feasible in most situations), it would be normally enough for practical purposes to find a *known* Pareto Optimal Set, termed  $P_{\text{known}}$ , with its corresponding Pareto Front  $PF_{\text{known}}$ , close enough to the true optimal solution [5].

### III. PROPOSED METHOD

A new approach based on the Strength Pareto Evolutionary Algorithm was developed for this work. This method, closely related to Genetic Algorithms [10], is based on generating a stored *External Population* composed by the best known individuals  $\mathbf{B}$  of a general evolutionary population. This external group of solutions conforms  $P_{\text{known}}$ , available at each moment of the computation, i.e., the best known approximation to  $P_{\text{true}}$ . The original SPEA evaluates an individual's fitness depending on the number of decision vectors it dominates in an evolutionary population, i.e., decision vectors that are not better in any objective function  $F_i$ , but with a worse objective function  $F_i$  for at least one value of  $i$ .

SPEA preserves population diversity using Pareto dominance relationship and incorporating a clustering procedure in order to reduce the nondominated set without destroying its characteristics. In general, cluster analysis partitions a collection of  $m$  elements into  $g$  groups of relatively homogeneous elements, where  $g < m$ , selecting a representative individual for each of the  $g$  clusters. That way, a fixed number of  $g$  individuals may be maintained in the external population preserving the main characteristics of the Pareto Front [7].

An important issue with SPEA is its converge property, assured by *Theorem 4* proved in [5], a characteristic not always present in other MOEAs. Consequently, the algorithm implemented for this work is based on the original SPEA [7], but differs from it in the following aspects:

- *Heuristic Initialization.* A special heuristic method is used to generate the initial population in order to obtain individuals electrically well compensated. The proposed heuristic is based on encouraging compensation at busbars with large number of branches and voltage profile far from the desired value. This is done by using a method summarized as follows:
  - a. Choose a total amount of compensation  $B_{\text{tot}}$ .
  - b. For each busbar  $i$  of the system, calculate a factor  $K_i$

using the following expression:

$$K_i = \begin{cases} (V_i - V_i^*) l_i & \text{if } V_i < V_i^* \\ 0 & \text{if } V_i \geq V_i^* \end{cases}$$

where  $l_i$  is the number of branches connected to node  $i$ .

$K_i = 0$  indicates that no reactive compensation is heuristically assigned to busbar  $i$ .

c. Normalize  $K_i$  using:

$$K'_i = \frac{K_i}{\sum_{i=1}^n K_i}$$

d. Compensate each busbar  $i$  with  $B_i$  calculated as follows:

$$B_i = K'_i B_{tot}$$

- *Local Optimization.* A special heuristic technique is implemented to improve individuals based on determining an adequate search direction using the power flow mismatch expression [4]:

$$\begin{bmatrix} \Delta P \\ \Delta Q \end{bmatrix} = \begin{bmatrix} \mathbf{J}_1 & \mathbf{J}_2 \\ \mathbf{J}_3 & \mathbf{J}_4 \end{bmatrix} \begin{bmatrix} \Delta \delta \\ \Delta V \end{bmatrix} \quad (8)$$

From (8) and neglecting  $\mathbf{J}_3$  as well as the non-diagonal elements of  $\mathbf{J}_4 = \{J_{4_{ij}}\}$ , the following expression is derived:

$$\Delta Q_i \approx J_{4_{ii}} \Delta V_i = J_{4_{ii}} (V_i^* - V_i) \quad (9)$$

where  $\Delta Q_i$  is the amount of reactive compensation to be added at busbar  $i$ .

- *Stop criterion.* Computation is halted when no new nondominated solution is found to dominate an individual of the external population for a given number  $N_{stop}$  of successive generations.

- *Two External Populations.* If only one external population is used, it is possible:

- a. to save all found Pareto solutions, but this population may become too large and the evolutionary population loses genetic importance in the search process; or
- b. to loose found solutions using clustering to maintain a given number  $g$  of external solutions (original SPEA approach).

In this new proposal, two external populations are stored, one with all found nondominated solutions and another

with a maximum number  $g$  of nondominated individuals, fixed by clustering, that participates in the ordinary evolutionary process. That way, the external population used in the evolutionary process does not diminish the influence of the evolutionary population and no optimal solution is lost. Note that this second external population may be stored on disk, because it does not participate in the evolutionary process.

- *Freezing.* Inspired in Simulated Annealing technique, probabilities (of mutation  $P_m$ , crossover  $P_c$  and for using the local optimization  $P_{lo}$ ) change with the number of generations and fitness value, freezing at the end of the computation to improve convergence [11].

The proposed method may be summarized as follows:

1. Generate an initial population  $Pop$  using the heuristic method previously exposed and create two empty external nondominated sets  $P_{known}$  and  $SP_{known}$  (stored external population).
2. Copy nondominated members of  $Pop$  to  $P_{known}$  and  $SP_{known}$ .
3. Remove individuals within  $SP_{known}$  which are covered (dominated) by any member of  $P_{known}$ .
4. Remove solutions within  $P_{known}$  which are covered by any member of  $SP_{known}$ .
5. If the number of externally nondominated solutions in  $P_{known}$  exceeds a given maximum  $g$ , clustering is applied in order to reduce the external population to a size  $g$ .
6. Calculate the fitness of each individual in  $Pop$  as well as in  $P_{known}$  using standard SPEA fitness assignment procedure.
7. Select individual from  $Pop + P_{known}$  (multiset union) until the mating pool is filled. In this study, roulette wheel selection is used.
8. Apply  $P_{lo}$ ,  $P_c$  and  $P_m$  to determine whether and individual is locally optimized or selected for crossover and mutation, in which case, standard genetic operators are applied.
9. Go to step 2 if stop criterion is not verified.

#### IV. EXPERIMENTAL ENVIRONMENT

As a study case, the IEEE 118 Bus Power Flow Test Case has been selected [12]. In order to stress the original system, its active and reactive loads were incremented by 40%, turning the power network in an adequate candidate for reactive power compensation.

For comparison purposes, the Pareto set generated by the proposed method has been compared to Pareto sets obtained using four different methods:

1. Compensation schemes elaborated by a team of specialized engineers using standard computational programs (*Specialist*).
2. Original SPEA implementation, with random initial population [7] (*SPEA*).
3. Original SPEA implementation with heuristic initialization (*SPEA<sup>+</sup>*).
4. A special SPEA with heuristic initialization and the mutation genetic operator replaced by the previous exposed local optimization (*SPEA<sup>lo</sup>*).

For the experimental results presented in the following section, it has been assumed that  $\alpha = \beta$ , i.e., capacitor and reactor banks have the same cost per MVar. At the same time,  $N_{stop} = 100$  was experimentally chosen.

To evaluate the experimental results using all five methods, an appropriate test suite metrics is used [5], because no single metric can entirely capture total MOEA performance, effectiveness and efficiency. The test suit comprises the following metrics:

#### 1) Overall Nondominated Vector Generation (*N*)

$$N \stackrel{\Delta}{=} |PF_{known}|_c$$

where  $|\cdot|_c$  denotes cardinality.

This metric indicates the number of solutions in  $PF_{known}$ . A good  $PF_{known}$  set is expected to have a large number of individuals, in order to offer a wide variety of options to the engineer.

#### 2) Overall Nondominated Vector Generation Ratio (*ONVGR*)

$$ONVGR \stackrel{\Delta}{=} \frac{N}{|PF_{true}|_c}$$

It denotes the ratio between the number of solutions in  $PF_{known}$  to the number of solutions in  $PF_{true}$ . Since the objective is to obtain a  $PF_{known}$  set as similar as possible to  $PF_{true}$ , a value near to 1 is desired.

#### 3) Error Ratio (*E*)

$$E \stackrel{\Delta}{=} \frac{\sum_{i=1}^N e_i}{N};$$

$$e_i = \begin{cases} 0 & \text{if a vector in } PF_{known} \text{ is also in } PF_{true} \\ 1 & \text{otherwise} \end{cases}$$

This ratio reports the proportion of objective vectors in  $PF_{known}$  that are not members of  $PF_{true}$ . Therefore; an Error Ratio  $E$  close to 1 indicates a poor correspondence between  $PF_{known}$  and  $PF_{true}$ , i.e.,  $E = 0$  is desired.

#### 4) Generational Distance (*G*)

$$G \stackrel{\Delta}{=} \frac{\left( \sum_{i=1}^N d_i^2 \right)^{1/2}}{N}$$

where  $d_i$  is the Euclidean distance (in objective space) between each objective vector  $\mathbf{F}$  in  $PF_{known}$  and its nearest member in  $PF_{true}$ . A large value of  $G$  indicates  $PF_{known}$  is far from  $PF_{true}$ , being  $G = 0$  the ideal situation.

#### 5) Maximum Pareto Front Error (*ME*)

$$ME \stackrel{\Delta}{=} \max_j \left( \min_i \|\mathbf{F}^i - \mathbf{F}^j\|_{\infty} \right)$$

$$\mathbf{F}^i \in PF_{true}; \quad \mathbf{F}^j \in PF_{known}$$

It indicates the maximum error band that, when considered with respect to  $PF_{known}$ , encompasses every vector in  $PF_{true}$ . Ideally,  $ME = 0$  is desired.

Since most of these metrics reflect the likeness between the true Pareto Front Optimal set  $PF_{true}$  and a computed Pareto Front set  $PF_{known}$ , a good approximation of  $PF_{true}$  is built by gathering all nondominated individuals from all five sets. In other words, for the following results,  $PF_{true}$  is approximated by the best known solutions of all our experiments.

### V. EXPERIMENTAL RESULTS

Tables I and II present experimental results using the IEEE-118 study case, showing the figures obtained by all five methods. For the methods used to compare the proposed approach, the best results obtained by a single run have been selected, having the SPEA implementations reached a stagnant population, i.e., no new solutions are obtained with new generations for  $N_{stop} = 100$  generations. On the other hand, the proposed method has been stopped using a maximum number of generation criterion, since it continues generating new solutions reaching more than 2000 stored solutions ( $SP_{known}$ ). This is an important advantage since it gives the user a wider variety of alternative solutions.

TABLE I  
EXPERIMENTAL RESULTS: 60 GENERATION RUN OF THE PROPOSED METHOD

Metrics	<i>Specialist</i>	<i>SPEA</i>	<i>SPEA<sup>+</sup></i>	<i>SPEA<sup>lo</sup></i>	<i>Proposed Method</i>
<i>N</i>	170	100	150	172	181
<i>ONVGR</i>	0.4315	0.2538	0.3807	0.4365	0.4594
<i>E</i>	0.2353	0.9500	0.9533	0.2558	0.2431
<i>G</i>	0.5702	0.7325	0.6060	0.5814	0.5431
<i>ME</i>	0.0852	0.1040	0.2332	0.0324	0.0554

Table I presents experimental results running only 60 generation of our proposed approach while the other methods run until convergence. Table II presents figures when the

proposed method run for 200 generations. In both tables, best figures are indicated by a shadowed cell.

TABLE II  
EXPERIMENTAL RESULTS: 200 GENERATION RUN OF THE PROPOSED METHOD

Metrics	<i>Specialist</i>	<i>SPEA</i>	<i>SPEA</i> <sup>+</sup>	<i>SPEA</i> <sup>lo</sup>	<i>Proposed Method</i>
<i>N</i>	170	100	150	172	222
<i>ONVGR</i>	0.4208	0.2475	0.3713	0.4257	0.5495
<i>E</i>	0.3235	0.9800	0.9867	0.4128	0.1486
<i>G</i>	0.6138	0.7635	0.6221	0.6022	0.5315
<i>ME</i>	0.0852	0.0948	0.2294	0.0462	0.0342

For the first two metrics *N* and *ONVGR*, it is clear that the proposed method has the best performance, since it generates the widest variety of solutions. This fact is even more evident when the stored external population is considered.

In Table I, the compensation set elaborated by the specialists has the smallest Error Ratio *E*, closely followed by the proposed method, what gives an idea of the good job being done by the engineers; however, with a greater number of generations, the proposed method improves sensitively its performance, reducing in nearly 40% its error ratio, outperforming other methods, as shown in Table II.

The values obtained for the Generational Distance *G* show that the proposed method has the best results in both tables, offering a  $PF_{known}$  set closer to  $PF_{true}$ .

Table I indicates that the proposed method occupies the second place in the Maximum Pareto Front Error (*ME*) ranking for a lower number of generations, beaten by the *SPEA*<sup>lo</sup> implementation. However, with a larger number of generations, the proposed method have the smallest *ME* value (see Table II).

A final fact to be emphasized is that the proposed method improves its performance for most metrics with a larger number of generations, while the other methods have converged before whole exploration of search space, what is known as premature convergence.

## VI. CONCLUDING REMARKS

In this paper, Reactive Compensation Problem is first treated as a *Multi-objective Optimization Problem* with 4 conflicting objective functions: (i) investment in reactive compensation devices, (ii) active power losses, (iii) average voltage deviation and (iv) maximum voltage deviation.

To solve the problem, a new approach based on *SPEA* is proposed. This new approach introduces several proposals as: (i) heuristic initialization, (ii) a local optimization technique, (iii) a stop criterion, (iv) two external populations and (v) a freezing feature.

For comparison purposes, the solution set obtained in a single run of the proposed method is compared to four sets of solutions calculated as the best of several runs using other

methods or as the best set of solutions calculated by a team of specialists.

Experimental results using the proposed approach demonstrated several advantages when using the proposed method, such as a set of solutions closer to the *True Pareto Set* outperforming other methods in every studied figure of merits, and a wider variety of options. This last feature is of special importance, since a richer set of alternatives are offered to the network planners. In order to select sub-sets of solutions which best fit the interests of the user, an adaptive constrain philosophy is suggested. That way, the network engineer may restrict the constraints to reduce the number of solutions after having a good idea of the whole Pareto solutions, searching forward only in the redefined domain. This process may continue iteratively until a good solution with an acceptable compromise among objective functions is found.

As future work, new specialized genetic operators are being developed to locally improve reactive compensation of a given individual. At the same time, other objective functions (such as voltage stability margin) are going to be considered. Finally, parallel asynchronous computation using a network of computers are considered for larger networks with more objective functions.

## REFERENCES

- [1] K. Miu, H. Chiang and G. Darling, " Capacitor Placement, Replacement and Control in Large-Scale Distribution Systems by a A-Based Two-Stage Algorithm," *IEEE Trans. Power Systems*, vol. 12, n° 3, pp. 1160-1166, Aug. 1997.
- [2] J. Carlisle, A. El-Keib, D. Boyd and K. Nolan, " A Review of Capacitor Placement Techniques on Distribution Feeders," in *Proc. 1997 IEEE 29th Southeastern Symposium on System Theory (SSST '97)*.
- [3] M. Delfanti, G. Granelli, P. Marannino and M. Montagna, " Optimal Capacitor Placement Using Deterministic and Genetic Algorithms," *IEEE Trans. Power Systems*, vol. 15, n° 3, pp. 1041-1046, Aug. 2000.
- [4] P. Kundur, *Power System Stability and Control*. New York: Mc Graw-Hill, 1993.
- [5] D. Van Veldhuizen, "Multiobjective Evolutionary Algorithms: Classifications, Analysis, and New Innovations," Ph.D. dissertation, Faculty of the Graduate School of Engineering , Air Force Institute of Technology, 1997.
- [6] B. Venkatesh, G. Sadasivam and M. Abdullah Khan, " A New Optimal Power Scheduling Method for Loss Minimization and Voltage Stability Margin Maximization Using Successive Multiobjective Fuzzy LP Technique," *IEEE Trans. Power Systems*, vol. 15, n° 2, pp. 844-851, May. 2000.
- [7] E. Zitzler and L. Thiele, " Multiobjective Evolutionary Algorithms: A comparative Case Study and the Strength Pareto Approach," *IEEE Trans. Evolutionary Computation*, vol. 3, n° 4, pp. 257-271, Nov. 1999.
- [8] H. Dommel and W. Tinney, " Optimal Power Flow Solutions, " *IEEE Trans. Power Apparatus and Systems*, vol. PAS-87, n° 10, pp. 1866-1876, Oct.. 1968.
- [9] J. D. Glover and M. Sarma, *Power System Analysis and Design*. Boston: PWS Publishing Company, 1994.
- [10] D. Goldberg, *Genetic Algorithm is Search, Optimization & Machine Learning*. New York: Addison Wesley, 1989.
- [11] Z. Dong, Y. Wang, D. Hill and Y. Makerov, " A New Approach to Power System VAR Planning Aimed at Voltage Stability Enhancement with Feedback Control," in *Proc. 1999 IEEE Powertech Conference*, paper BPT-212-24.
- [12] R. Christie, " Power Systems Test Case Archive," Electrical Engineering dept., University of Washington, Apr. 2000. [Online]. Available: <http://www.ee.washington.edu/research/pstca>.